

Candia, Town

# Above Ground Propane Tank

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-089AT

Date of Issue

4/01/2024

Expiration Date

4/01/2025

Owner: LEMIEUX, RYAN & VICTORIA

Applicant: DEAD RIVER COMPANY

Location of Work: 56 PALMER ROAD  
(No. and Street) (Unit or Building)

Description of Work: SWAP OUT 1-120 PROPANE TANK

**ZONING DATA:** District: RES Map/Lot: 414-054

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: DEAD RIVER COMPANY (603) 625-8531


**REMARKS:**

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.  
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.  
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.  
BACK FILL WITH CLEAN MATERIAL.  
LINE SETS MUST HOLD 15 LB FOR 10 MIN.  
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: DEAD RIVER COMPANY  
(Taking Responsibility for the Work)  
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$100.00 Check No.: Cash: \$100.00

The Permit Card Shall be Posted and Visible From the Street During Construction

  
Code Official

04-01-2024  
Date