



Candia, Town

GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-098GP

Date of Issue

4/10/2024

Expiration Date

4/10/2025

Owner: SILVEIRA, JOSEPH A. & HEATHER J.

Applicant: JN ELECTRIC LLC

Location of Work: 111 TOWER HILL ROAD
(No. and Street) (Unit or Building)

Description of Work: INSTALL NEW 14KW GENERATOR

ZONING DATA: District: RES Map\Lot: 411-008

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO

Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: JN ELECTRIC LLC 553-9897


REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: JN ELECTRIC LLC (Taking Responsibility for the Work)
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0	Permit Fee: \$110.00	Check No.: 1185	Cash: \$0.00
-------------------------	-----------------------------	------------------------	---------------------

The Permit Card Shall be Posted and Visible From the Street During Construction

 Code Official	04-10-2024 Date
--	--------------------