

Candia, Town

GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-076GP

Date of Issue

3/18/2024

Expiration Date

3/18/2025

Owner: LOCKE, JEFFREY

Applicant: Eastern Propane Gas Inc

Location of Work: 65 MAIN STREET
(No. and Street) (Unit or Building)

Description of Work: INSTALL 50 FEET OF COPPER LINE TO STUB OUT

ZONING DATA: District: RES Map/Lot: 409-212-C

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO

Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Eastern Propane Gas Inc 883-6400


REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: Eastern Propane Gas Inc
(Taking Responsibility for the Work)
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$110.00 Check No.: 25559 Cash: \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official 03-18-2024
Date