

Candia, Town

# FUEL OIL TANK

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2023-347FT

Date of issue

8/15/2023

Expiration Date

8/14/2024

Owner: CUNNINGHAM, SCOT W & MELINDA A

Applicant: RICK WENZEL OIL COMPANY, LLC

Location of Work: 133 LANGFORD ROAD  
(No. and Street) (Unit or Building)

Description of Work: INSTALL 265 GAL OIL TANK

**ZONING DATA:** District: RES Map\Lot: 408-017

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: RICK WENZEL OIL COMPANY, LLC 603-673-9554

**REMARKS:**


1. FUEL OIL STORAGE TANKS SHALL BE LISTED AND LABELLED FOR SPECIFIED USE.
2. FUEL TANK SHALL BE INSTALLED IN COMPLIANCE WITH APPLICABLE NFPA CODES.
3. PROPER SUPPORT IS REQUIRED AND MUST BE LOCATED NO LESS THAN 5 FEET FROM BURNER.
4. MINIMUM 1 1/4" VENT PIPE WITH ALARM IS REQUIRED.
5. FUEL OIL TANK SHALL BE SECURELY ANCHORED TO PREVENT FLOTATION. NONCOMBUSTIBLE STRAPS OR RIGID FASTENER TO THE TOP IS REQUIRED.
6. MAXIMUM TANK SIZE ALLOWED IS 330 GALLONS WITH A COMBINED STORAGE NOT TO EXCEED 660 GALLONS.
7. PROPER SPACING TO WINDOWS OR OTHER OPENINGS INTO BUILDING MUST BE MAINTAINED..
8. VENT PIPE MUST SLOPE DOWN TO TANK.
9. THERMAL AND MAMUAL FUEL SHUTOFF IS REQUIRED AT BOTTOM OF TANK AND AT BURNER.
10. CONTACT THIS OFFICE FOR INSPECTION WHEN WORK IS COMPLETE.

Permit Holder: RICK WENZEL OIL COMPANY, LLC  
(Taking Responsibility for the Work)

Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$100.00 Check No.: 1021 Cash: \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction

  
Code Official

08-15-2023  
Date