

Candia, Town  
**ABOVE GROUND LP TANK**

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015  
Inspections - Mon, Tues & Thurs afternoons

**Permit Number**  
2023-365GT  
**Date of Issue**  
8/28/2023  
**Expiration Date**  
8/27/2024

**Owner:** FLACHBART THOMAS

**Applicant:** RICHARD ENERGY

**Location of Work:** 89 LANDING WAY 406-140-20  
(No. and Street) (Unit or Building)

**Description of Work:** place two 120 gal propane tanks  
PAID WITH TWO CHECKS 22091 & 22155

**ZONING DATA:** District: RES Map/Lot:

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:

**Design Occupant Load:** Total Number of Dwelling Units: 0 Construction Area:

**Building / Addition:** Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

**REMARKS:**

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.  
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.  
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.  
BACK FILL WITH CLEAN MATERIAL.  
LINE SETS MUST HOLD 15 LB FOR 10 MIN.  
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

**Permit Holder:** RICHARD ENERGY


(Taking Responsibility for the Work)

**Company/Affiliation:** Contractor

**Job Site Phone Number:**

**Constr Cost:** \$0 **Permit Fee:** \$100.00 **Check No.:** 22091 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction

  
Code Official

08-28-2023  
Date