

Candia, Town
GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number

2023-432GP

Date of Issue

10/24/2023

Expiration Date

10/23/2024

Owner: PARKMAN, NANCY

Applicant: Heritage Plumbing and Heating

Location of Work: 46 LANGFORD ROAD
(No. and Street) (Unit or Building)

Description of Work: 10 FEET OF GAS PIPING FOR WALL HEATER

ZONING DATA: District: RES Map\Lot: 408-056

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO

Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Heritage Plumbing and Heating 603-668-4438

REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: Heritage Plumbing and Heating
(Taking Responsibility for the Work)
Company/Affiliation: Contractor **Job Site Phone Number:**

Constr Cost: \$0 **Permit Fee:** \$110.00 **Check No.:** 3811 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official 10-24-2023
Date