

Candia, Town
GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number
2023-437GP
Date of Issue
10/25/2023
Expiration Date
10/24/2024

Owner: BUTURA ANTONIO

Applicant: Proulx Oil & Propane

Location of Work: 403 NEW BOSTON ROAD
(No. and Street) (Unit or Building)

Description of Work: INSTALL 20 FEET OF GAS PIPING UNDERGROUND TANK TO GENERATOR

ZONING DATA: District: RES Map\Lot: 402-108

CONSTRUCTION DATA: Use Group: Min. Type Constr:
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Proulx Oil & Propane 659-7011


REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: Proulx Oil & Propane
(Taking Responsibility for the Work)
Company/Affiliation: Contractor **Job Site Phone Number:**

Constr Cost: \$0 **Permit Fee:** \$110.00 **Check No.:** 3013 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official

10-25-2023
Date