

Candia, Town

# GAS PIPING PERMIT

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2023-477GL

Date of Issue

12/05/2023

Expiration Date

12/04/2024

**Owner:** GOODWIN, WAYNE R REVOCABLE TRU GOODWIN, LAURIE J REVOCABLE TR

**Applicant:** JN ELECTRIC LLC

**Location of Work:** 591 CHESTER TURNPIKE  
(No. and Street) (Unit or Building)

**Description of Work:** gas piping for new generator

**ZONING DATA:** District: RES Map\Lot: 404-016-2

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:  
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

**Building / Addition:** Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

**CONTRACTOR:** JN ELECTRIC LLC 553-9897

**REMARKS:**

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.  
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.  
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

**Permit Holder:** JN ELECTRIC LLC  
(Taking Responsibility for the Work)  
**Company/Affiliation:** Contractor **Job Site Phone Number:**

**Constr Cost:** \$0 **Permit Fee:** \$110.00 **Check No.:** 1135 **Cash:** \$0.00

**The Permit Card Shall be Posted and Visible From the Street During Construction**

  
**Code Official** 12-05-2023  
**Date**