

Candia, Town
Above Ground Propane Tank

Building & Inspection Department
74 High Street, Candia, NH 03034

603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2023-481 AT

Date of Issue

12/11/2023

Expiration Date

12/10/2024

Owner: DREW, LEONARD & DIANE TRUSTEES DREW FAMILY REV. TRUST

Applicant: COTE ELECTRIC

Location of Work: 47 PINE RIDGE DRIVE
(No. and Street) (Unit or Building)

Description of Work: PLACE 2-120 GAL PROPANE TANKS FOR GENERATOR

ZONING DATA: District: RES Map/Lot: 410-061

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: COTE ELECTRIC 624-7970

REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: COTE ELECTRIC

(Taking Responsibility for the Work)

Company/Affiliation: Contractor

Job Site Phone Number:

Constr Cost: \$0 **Permit Fee:** \$100.00 **Check No.:** 3752 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official

12-11-2023
Date