

Candia, Town

GAS PIPING PERMIT

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-069GP

Date of Issue

3/13/2024

Expiration Date

3/13/2025

Owner: DEVLIN MARY

Applicant: Wickson NRG LLC

Location of Work: 191 MAIN STREET
(No. and Street) (Unit or Building)

Description of Work: GAS PIPING FOR NEW COOKING STOVE

ZONING DATA: District: RES Map\Lot: 409-043

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO

Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Wickson NRG LLC 890-7051


REMARKS:

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: Wickson NRG LLC
(Taking Responsibility for the Work)
Company/Affiliation: Contractor **Job Site Phone Number:**

Constr Cost: \$0 **Permit Fee:** \$110.00 **Check No.:** 3080 **Cash:** \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official **03-13-2024**
Date