

Candia, Town

FUEL OIL TANK

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-085FT

Date of Issue

3/27/2024

Expiration Date

3/27/2025

Owner: LAMBERT, MICHAEL P. & ALYSSA K.

Applicant: MACK'S HEATING AND A/C

Location of Work: 40 HOOK ROAD
(No. and Street) (Unit or Building)

Description of Work: REMOVE AND REPLACE OIL TANK.

ZONING DATA: District: RES Map/Lot: 413-027

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

REMARKS:

1. FUEL OIL STORAGE TANKS SHALL BE LISTED AND LABELLED FOR SPECIFIED USE.
2. FUEL TANK SHALL BE INSTALLED IN COMPLIANCE WITH APPLICABLE NFPA CODES.
3. PROPER SUPPORT IS REQUIRED AND MUST BE LOCATED NO LESS THAN 5 FEET FROM BURNER.
4. MINIMUM 1 1/4" VENT PIPE WITH ALARM IS REQUIRED.
5. FUEL OIL TANK SHALL BE SECURELY ANCHORED TO PREVENT FLOTATION. NONCOMBUSTIBLE STRAPS OR RIGID FASTENER TO THE TOP IS REQUIRED.
6. MAXIMUM TANK SIZE ALLOWED IS 330 GALLONS WITH A COMBINED STORAGE NOT TO EXCEED 660 GALLONS.
7. PROPER SPACING TO WINDOWS OR OTHER OPENINGS INTO BUILDING MUST BE MAINTAINED..
8. VENT PIPE MUST SLOPE DOWN TO TANK.
9. THERMAL AND MAMUAL FUEL SHUTOFF IS REQUIRED AT BOTTOM OF TANK AND AT BURNER.
10. CONTACT THIS OFFICE FOR INSPECTION WHEN WORK IS COMPLETE.

Permit Holder: MACK'S HEATING AND A/C (Taking Responsibility for the Work)	
Company/Affiliation: Contractor	Job Site Phone Number:

Constr Cost: \$0	Permit Fee: \$100.00	Check No.: 1302	Cash: \$0.00
-------------------------	-----------------------------	------------------------	---------------------

The Permit Card Shall be Posted and Visible From the Street During Construction

<hr/> Code Official	<hr/> Date
----------------------------	-------------------