

Candia, Town
Above Ground Propane Tank

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number
2024-125AT
Date of Issue
5/08/2024
Expiration Date
5/08/2025

Owner: SPERO, JOSHUA & CHRISTINE

Applicant: DEAD RIVER COMPANY

Location of Work: 205 TOWER HILL ROAD
(No. and Street) (Unit or Building)

Description of Work: SWAP OUT TWO 120 GAL PROPANE TANKS

ZONING DATA: District: RES Map/Lot: 411-002

CONSTRUCTION DATA: Use Group: Min. Type Constr:
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:
Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: DEAD RIVER COMPANY (603) 625-8531

REMARKS:

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.
BACK FILL WITH CLEAN MATERIAL.
LINE SETS MUST HOLD 15 LB FOR 10 MIN.
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: DEAD RIVER COMPANY (Taking Responsibility for the Work)
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0	Permit Fee: \$100.00	Check No.:	Cash: \$100.00
-------------------------	-----------------------------	-------------------	-----------------------

The Permit Card Shall be Posted and Visible From the Street During Construction

 Code Official	05-08-2024 Date
--	--------------------