

Candia, Town
UNDERGROUND TANK

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015
Inspections - Mon, Tues & Thurs afternoons

Permit Number
2024-133UG
Date of Issue
5/13/2024
Expiration Date
5/13/2025

Owner: LEBLANC MIKE

Applicant: Wickson NRG LLC

Location of Work: 96 DEERFIELD ROAD
(No. and Street) (Unit or Building)

Description of Work: INSTALL NEW 500 GAL IN GROUNG PROPANE TANK

ZONING DATA: District: RES Map\Lot: 406-028

CONSTRUCTION DATA: Use Group: Min. Type Constr:
Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:
Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Wickson NRG LLC 890-7051


REMARKS:

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.
TANKS MUST BE LISTED, LABLED AND HAVE UPDATED DATE CODES.
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.
BACK FILL WITH CLEAN MATERIAL.
LINE SETS MUST HOLD 15 LB FOR 10 MIN.
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: Wickson NRG LLC (Taking Responsibility for the Work)	
Company/Affiliation: Contractor	Job Site Phone Number:

Constr Cost: \$0	Permit Fee: \$100.00	Check No.: 3105	Cash: \$0.00
-------------------------	-----------------------------	------------------------	---------------------

The Permit Card Shall be Posted and Visible From the Street During Construction

 Code Official	05-13-2024 Date
--	--------------------