

Candia, Town
Above Ground Propane Tank

Building & Inspection Department
74 High Street, Candia, NH 03034
603-483-1015

Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-138AT

Date of Issue

5/21/2024

Expiration Date

5/21/2025

Owner: PEPPER, BILLIE R. & MARK

Applicant: Buxton Oil

Location of Work: 376 CRITCHETT ROAD
(No. and Street) (Unit or Building)

Description of Work: SWAP OUT 1- 120 GAL PROPANE TANK

ZONING DATA: District: RES Map/Lot: 407-029

CONSTRUCTION DATA: Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO

Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: Buxton Oil 679-5600


REMARKS:

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.
TANKS MUST BE LISTED, LABELED AND HAVE UPDATED DATE CODES.
ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.
BACK FILL WITH CLEAN MATERIAL.
LINE SETS MUST HOLD 15 LB FOR 10 MIN.
CALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Permit Holder: Buxton Oil
(Taking Responsibility for the Work)
Company/Affiliation: Contractor **Job Site Phone Number:**

Constr Cost: \$0 **Permit Fee:** \$100.00 **Check No.:** **Cash:** \$100.00

The Permit Card Shall be Posted and Visible From the Street During Construction


Code Official

05-21-2024
Date