

Candia, Town

# GAS PIPING PERMIT

Building & Inspection Department  
74 High Street, Candia, NH 03034  
603-483-1015  
Inspections - Mon, Tues & Thurs afternoons

Permit Number

2024-189GP

Date of Issue

7/10/2024

Expiration Date

7/10/2025

Owner: COUGHLIN, KEVIN S & BRENDA L TRUSTEES KB COUGHLIN TRUST

Applicant: JN ELECTRIC LLC

Location of Work: 96 LANGFORD ROAD  
(No. and Street) (Unit or Building)

Description of Work: GAS LINE FOR NEW GENERATOR

**ZONING DATA:** District: RES Map/Lot: 408-060-3

**CONSTRUCTION DATA:** Use Group: Min. Type Constr:

Design Occupant Load: Total Number of Dwelling Units: 0 Construction Area:

Building / Addition: Change in FootPrint: NO Irregular Size, See Plan: NO  
Length: 0 FT. Width: 0 FT. Height: 0 FT. Number of Stories: 0.00

CONTRACTOR: JN ELECTRIC LLC 553-9897

**REMARKS:**

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.  
AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.  
FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Permit Holder: JN ELECTRIC LLC  
(Taking Responsibility for the Work)  
Company/Affiliation: Contractor Job Site Phone Number:

Constr Cost: \$0 Permit Fee: \$110.00 Check No.: 1269 Cash: \$0.00

The Permit Card Shall be Posted and Visible From the Street During Construction

  
Code Official Date: 07-10-2024