

# TOWN OF CANDIA

## GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-215 Date: 07/29/2024  
Map: 000407 Lot: 000006 Sub Lot: 000000

Permit issued to: MANNION, THOMAS  
at: 54 ISLAND RD

Owner Address: 54 ISLAND ROAD CANDIA, NH 03034 | Phone:

Applicant: EASTERN PROPANE | Phone:


Contractor: EASTERN PROPANE | Phone: | License #:

Permit Fee: \$110.00 | Estimated Cost: \$0

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  Telephone: (603) 483-1015  
Building Inspector

**NOTE: THIS PERMIT EXPIRES JULY 29, 2025.**