



# TOWN OF CANDIA

## GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

**Permit Number:** 2024-330 **Date:** 09/23/2024  
**Map:** 000409 **Lot:** 000092 **Sub Lot:** 000000

Permit issued to: PONTIDIS, NIKI & SOULIOS, XANTHI  
at: 3 MAIN ST

**Owner Address:** 409 CENTRAL STREET MANCHESTER, NH 03103 | Phone:

**Applicant:** QUEEN CITY HVAC LLC | Phone:

**Contractor:** QUEEN CITY HVAC LLC | Phone: | License #:


**Permit Fee:** \$110.00 | **Estimated Cost:** \$0

**NOTE:** REPLACING 25 FEET OF GAS LINE

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

**Signed:**  **Telephone:** (603) 483-1015  
Building Inspector

**NOTE: THIS PERMIT EXPIRES SEPTEMBER 23, 2025.**