

TOWN OF CANDIA

FUEL OIL TANK PERMIT



The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-337 Date: 09/26/2024
Map: 000413 Lot: 000015 Sub Lot: 000000

Permit issued to: POLLARD, JUDITH A.

at: 223 BROWN RD


Owner Address: 223 BROWN ROAD CANDIA, NH 03034 | Phone:

Applicant: PATRIOT HEATING AND COOLING LLC | Phone:

Contractor: PATRIOT HEATING AND COOLING LLC | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

1. FUEL OIL STORAGE TANKS SHALL BE LISTED AND LABELLED FOR SPECIFIED USE.
2. FUEL TANK SHALL BE INSTALLED IN COMPLIANCE WITH APPLICABLE NFPA CODES.
3. PROPER SUPPORT IS REQUIRED AND MUST BE LOCATED NO LESS THAN 5 FEET FROM BURNER.
4. MINIMUM 1 1/4" VENT PIPE WITH ALARM IS REQUIRED.
5. FUEL OIL TANK SHALL BE SECURELY ANCHORED TO PREVENT FLOTATION. NONCOMBUSTIBLE STRAPS OR RIGID FASTENER TO THE TOP IS REQUIRED.
6. MAXIMUM TANK SIZE ALLOWED IS 330 GALLONS WITH A COMBINED STORAGE NOT TO EXCEED 660 GALLONS.
7. PROPER SPACING TO WINDOWS OR OTHER OPENINGS INTO BUILDING MUST BE MAINTAINED..
8. VENT PIPE MUST SLOPE DOWN TO TANK.
9. THERMAL AND MAMUAL FUEL SHUTOFF IS REQUIRED AT BOTTOM OF TANK AND AT BURNER.
10. CONTACT THIS OFFICE FOR INSPECTION WHEN WORK IS COMPLETE.

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES SEPTEMBER 26, 2025.