



TOWN OF CANDIA GAS PIPING PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-344 **Date:** 09/30/2024
Map: 000411 **Lot:** 000002 **Sub Lot:** 000000

Permit issued to: 16 COLLENY DRIVE LLC
at: 205 TOWER HILL RD

Owner Address: 1662 ELM STREET MANCHESTER, NH 03101 | Phone:

Applicant: LEMIRE HOMES | Phone:

Contractor: LEMIRE HOMES | Phone: | License #:


Permit Fee: \$180.00 | **Estimated Cost:** \$0

NOTE: GAS PIPING FOR NEW ADDITION.

A PRESSURE TEST MUST BE PERFORMED AND WITNESSED BY THE BUILDING INSPECTOR PRIOR TO ENERGIZING THE GAS PIPING.

AN APPROVAL TAG WILL BE ATTACHED TO THE PIPING WHEN APPROVED FOR CONNECTION.

FOR CSST FLEXIBLE GAS PIPING AN ELECTRICAL BONDING WIRE OF MINIMUM #6 COPPER MUST BE PROVIDED AS SPECIFIED IN THE MANUFACTURERS INSTALLATION INSTRUCTIONS AND THE NATIONAL ELECTRIC CODE ARTICLE 250.104 (B)

Signed:  **Telephone:** (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES SEPTEMBER 30, 2025.