

TOWN OF CANDIA

PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-347 Date: 09/30/2024
Map: 000405 Lot: 000076 Sub Lot: 000015

Permit issued to: SMITH AUSTIN PAUL
at: 60 CANDIA HIGHLANDS

Owner Address: 60 HIGHLAND STREET CANDIA, NH 03034 | Phone:

Applicant: IRVING OIL | Phone:

Contractor: IRVING OIL | Phone: | License #:

Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: REPLACE TWO 120 GAL PROPANE TANKS

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.

TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

GALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:



Building Inspector

Telephone:

(603) 483-1015

NOTE: THIS PERMIT EXPIRES SEPTEMBER 30, 2025.