

TOWN OF CANDIA

PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

Permit Number: 2024-391 Date: 10/22/2024
Map: 000413 Lot: 000078 Sub Lot: 000000

Permit issued to: AUCOIN IAN & BOSCO TAYLOR
at: 15 HEMLOCK DR

Owner Address: 36 SOUTH ROAD APT DERRY, NH 03038 | Phone:
Applicant: PALMER GAS COMPANY | Phone:
Contractor: PALMER GAS COMPANY | Phone: | License #:
Permit Fee: \$100.00 | Estimated Cost: \$0

NOTE: INSTALL 2-120 GAL PROPANE TANKS TO REPLACE EXISTING

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

GALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

Signed:  Telephone: (603) 483-1015
Building Inspector

NOTE: THIS PERMIT EXPIRES OCTOBER 22, 2025.