



# TOWN OF CANDIA GENERATOR PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

**Permit Number:** 2024-394 **Date:** 10/23/2024  
**Map:** 000402 **Lot:** 000066 **Sub Lot:** 000006


**Permit issued to:** CROSS-POWERS, MARK S & KARIN L  
**at:** 49 MAYHEW DR

**Owner Address:** 49 MAYHEW DRIVE CANDIA, NH 03034 | **Phone:** \_\_\_\_\_  
**Applicant:** KEVIN KELLY | **Phone:** \_\_\_\_\_  
**Contractor:** KEVIN KELLY | **Phone:** \_\_\_\_\_ | **License #:** \_\_\_\_\_  
**Permit Fee:** \$110.00 | **Estimated Cost:** \$0

**NOTE:** INSTALL NEW 22KW GENERATOR

**BACKUP ELECTRIC GENERATOR:**

- ELECTRIC CONNECTIONS MUST BE COMPLETED BY A KNOWLEDGABLE INDIVIDUAL IN CONFORMANCE CURRENTLY ADOPTED ELECTRIC CODES.
- AN ELECTRIC PERMIT MUST BE OBTAINED PRIOR TO PERFORMING ANY ELECTRIC WORK.
- LP GAS PIPING MUST BE INSTALLED AND CONNECTED BY A KNOWLEDGABLE INDIVIDUAL IN CONFORMANCE WITH NFPA 54 AND NFPA 37.
- A GAS PIPING PERMIT MUST BE OBTAINED PRIOR TO INSTALLING ANY GAS PIPING.
- IF GAS PIPING IS BURIED, INSPECTION IS REQUIRED PRIOR TO BACKFILLING.
- GENERATOR MUST BE LOCATED IN COMPLIANCE WITH STATE FIRE MARSHAL INFORMATION BULLETIN ON RESIDENTIAL GENERATOR SAFETY REVISED JUNE 22, 2009.

**Signed:**  **Telephone:** (603) 483-1015  
**Building Inspector**

**NOTE: THIS PERMIT EXPIRES OCTOBER 23, 2025.**