



# TOWN OF CANDIA PROPANE TANK PERMIT

The Permit Card Shall be Posted and Visible From the Street During Construction

**Permit Number:** 2025-007 **Date:** 01/07/2025  
**Map:** 000409 **Lot:** 000116 **Sub Lot:** 000001

Permit issued to: 304 RAYMOND LLC  
at: 304 RAYMOND RD

**Owner Address:** 22 BRADY DR HUDSON, NH 03051 | **Phone:**  
**Applicant:** PALMER GAS COMPANY | **Phone:**  
**Contractor:** PALMER GAS COMPANY | **Phone:** | **License #:**  
**Permit Fee:** \$110.00 | **Estimated Cost:** \$0

**NOTE:** INSTALL 1- 120 GAL PROPANE TANK FOR HEAT

ALL ABOVE AND BELOW GROUND TANKS MUST COMPLY WITH NFPA 58 2015.


TANKS MUST BE LISTED, CABLED AND HAVE UPDATED DATE CODES.

ALL BELOW GROUND TANKS MUST HAVE ANODE BAGS SET.

BACK FILL WITH CLEAN MATERIAL.

LINE SETS MUST HOLD 15 LB FOR 10 MIN.

GALL FOR INSPECTIONS 24 HOUR IN ADVANCE.

**Signed:**  **Telephone:** (603) 483-1015  
Building Inspector

**NOTE: THIS PERMIT EXPIRES JANUARY 07, 2026.**